

## TOWN OF HOLLISTON FACILITIES DEPARTMENT

1750 Washington St Holliston, MA 01746 508-958-4416 April 5, 2024

## ADDENDUM #1 ADAMS AUDITORIUM RTU REPLACEMENT

Attached please find an image of the data plate on the existing Roof Top Unit.

AAON, Inc.  TULSA, OKLAHOMA  ANSI ZZI-CAN CSA-1983 CENTRAL FURNACE  MODEL NUMBER 27236  RF-060-3-E0-313: MFBHHA00D0000X  SERIAL NUMBER 200001-AFGC00012  ELECTRICAL RAITNG							CONFORMS TO ULSTANDARD CERTIFIED TO CAN CSASTD C222 NO						
RATED VOLIS 460 VAC 60 H						3 PHASE							
MINIMUM CIRCUIT AMPACITY 134 AMPS						MAXIMUM FUSE							
MAXIMUM CIRCUIT BREAKER (HACR TYPE) 150						AMP							
MOTOR	QIY	HP	VAC	PH	RPM	FLA							
Compressor	4		460	3	3450		24	. 3	135			120	
Compressor													
Condenser	2	3	460	3	1140	4.8							
Evaporator	1	15	460	3	1725	21							
Combustion Air	2	.5	460	3	1725	1.1							
Power Exh.	1	3	460	3	1140	4.8							
Add Mtr.													
EQUIPPED FOR GAS NAT TEMPERATURE RISE RANGE 55-85 TEMPERATURE RISE  MANIFOLD PRESS. 3.5 WC MAX INLET PRESS. 10.5 WC MIN. INLET PRESS.  CAPACITY INPUT MBH OUTPUT MBH  DESIGN MAXIMUM OUTLET													
TEMPERATURE 185 °F				0-2000 Ft.		1165		885					
MANIMUM LIMIT SETTING 220 °F				2000-4	4500 Ft.								
CLEARANCES FLOOR - UNIT MUST BE IN (CANADA & USA) OR CLAS					GAS HE	AT UNIT MAY	YOPER	ATE (					

END OF DOCUMENT